



PAMANTASAN NG LUNGSOD NG MAYNILA
(University of the City of Manila)
Intramuros, Manila

Telefax: 528-4592

NAME OF PROJECT : **MATERIALS FOR THE REHABILITATION OF GUSALING LACSON - REBIDDING**

SUPPLEMENTAL/BID BULLETIN No. 27-G-18
03 October 2018

This Supplemental/Bid Bulletin is issued to clarify or amend some provisions originally indicated in the Bidding Documents addressed during the Pre-bid Conference held on **25 September 2018**, in compliance with Section 22.5.1 of the Revised Implementing Rules and Regulations of Republic Act 9184, to wit:

Issue/Clarification (ORIGINAL)	Response (AMENDED, see capitalization and underlined words)
Instruction to Bidders 5.4 xxx For this purpose, similar contracts shall refer to Supply and Delivery of uPVC Windows Technical Specifications Lot 1. uPVC Windows Warranty: At least 5 years Special Conditions of the Contract <ul style="list-style-type: none">17.3 One (1) year after acceptance by the Procuring Entity of the delivered Goods	Instruction to Bidders 5.4 xxx For this purpose, similar contracts shall refer to Supply, Delivery and Rehabilitation/Renovation/Installation involving uPVC Windows Technical Specifications Lot 1. uPVC Windows, uPVC Profile color white at least 2" thick, uPVC Window Glass 6mm thickness Annealed Glass Warranty: At least 2 years Special Conditions of the Contract <ul style="list-style-type: none">17.3 Two (2) years after acceptance by the Procuring Entity of the delivered Goods

This shall form an integral part of the bidding documents. Any provisions in the Bidding Documents inconsistent herewith is hereby cancelled, modified and superseded accordingly.

For guidance and information of all concerned.

Sgd.
Engr. KAREN L. LEYSON
Chief, PSO
PMO

Sgd.
ATTY. RUFINO V. ABUDA
PLM-BAC Chairperson

Received by the bidder:

Name of the Bidder & Signature

Name of Company

Date: _____